

Reacción al fuego



La Sociedad:

CMO
5 RUE CHABANAIS
FR-75002 PARIS

Está autorizada para colocar la etiqueta "Clasificación de Reacción al Fuego de Productos de Construcción" según el Nº de informe 2017AN2926



aitex
textile research institute

**CLASIFICACIÓN DE REACCIÓN AL FUEGO DE:
PRODUCTOS DE CONSTRUCCIÓN**

Nº 17AN2926

La muestra referenciada como:

"CMO WRA 04"

ha sido objeto de ensayo de acuerdo con las normas UNE-EN ISO 11925-2:2011 (equivalente a EN ISO 11925-2:2010) y UNE-EN 13823:2012+A1:2016 (equivalente a EN 13823:2010+A1:2014), quedando clasificada según norma UNE-EN 13501-1:2007+A1:2010 (equivalente a EN 13501-1:2007+A1:2009) como:

"B-s1,d0"

Alcoy, 30 de Noviembre de 2017.



Celia Dolça
RESPONSABLE LAB. COMPORTAMIENTO AL FUEGO

Reaction to fire



The applicant:

CMO
5 RUE CHABANAIS
FR-75002 PARIS

is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the report N° 2017AN2926



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 17AN2926

The sample reference:

"CMO WRA 04"

has been tested according to the standards UNE-EN ISO 11925-2:2011 (equivalent to EN ISO 11925-2:2010) and UNE-EN 13823:2012+A1:2016 (equivalent to EN 13823:2010+A1:2014). The classification according to standard UNE-EN 13501-1:2007+A1:2010 (equivalent to EN 13501-1:2007+A1:2010) is:

"B-s1,d0"

Alcoy, November 30th 2017.



Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.