

REACTION TO FIRE

Applicant:

CMO PARIS

35 RUE DE BELLECHASSE FR-75007 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2022AN6765.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS



Nº: 22AN6765

The sample referenced as:

"CMO WSO 02"



has been tested according to the standards
. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

3rd of October 2022



Celia Dolçà Head of Fire Behaviour lab.