



aitex®
research & innovation center

REACTION TO FIRE

Applicant:

CMO PARIS

35 RUE DE BELLECHASSE
FR-75007 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2023AN2648.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 23AN2648

The sample referenced as:

"CMO WCA 03"

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

29th of January 2024

Date: 29/01/2024 18:25:51

Digitally Signed by: GEMA ESTEVE SILVESTRE -

NIF: 21666152Z

Celia Dolça
Head of Fire Behaviour lab.