



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

CMO PARIS

35 RUE DE BELLECHASSE
FR-75007 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN0632.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN0632

The sample referenced as:

"WAB 09"

has been tested according to the standards EN ISO 11925-2:2020 & EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"C-s1,d0"

Date of Issue

25th of March 2025



Date: 26/03/2025 12:55:20

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.