

REACTION TO FIRE

Applicant:

CMO PARIS

35 RUE DE BELLECHASSE
FR-75007 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN0630.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN0630

The sample referenced as:

"CMO_WMA-01-02"

has been tested according to the standards EN ISO 11925-2:2020 & EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"C-s1,d0"

Date of Issue

1st of April 2025

Date: 01/04/2025 18:15:22

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.