



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN3291.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN3291

The sample referenced as:

"WAB 12"

has been tested according to the standards EN ISO 11925-2:2020. The classification according to standard EN 13501-1:2018 is:

"E"

Date of Issue

17th of December 2025



Date: 02/01/2026 12:12:55

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.