

REACTION TO FIRE

Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2026AN0455.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 26AN0455

The sample referenced as:

"WAB 16"

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"C-s1,d0"

Date of Issue

9th of March 2026



Date: 10/03/2026 13:30:09

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.