



**aitex**<sup>®</sup>  
research & innovation center

## REACTION TO FIRE

### Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER  
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN3297.



### CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN3297

The sample referenced as:

**"WAB 17"**

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

**"C-s1,d0"**

Date of Issue

8th of January 2026



Date: 09/01/2026 11:29:00

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño  
Head of Fire Behaviour lab.