

## REACTION TO FIRE

### Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER  
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2026AN0461.



### CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 26AN0461

The sample referenced as:

**"WPA 07 - WPA 08"**

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

**"D-s2,d0"**

Date of Issue

9th of March 2026

Date: 10/03/2026 13:33:47

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño  
Head of Fire Behaviour lab.